



CERTIFICATE OF COMPLIANCE

Number: 5046/C549D
Dated: 29 June 1998

Issued to: CMP PRODUCTS

Apparatus: P2K (POSEIDON 2000) CABLE GLAND RANGE

This is to certify that samples of the equipment defined above have been tested by ERA Technology Limited and found to comply with the following requirements:

BS EN 60529 : 1992 "Degrees of protection provided by enclosures (IP Code)" for a Degree of Protection IP66, IP67 AND IP68.

Full details are given in ERA Report No: 5046/549A dated June 1998.

Certificate prepared by:

A T Austin
Senior Technical Officer
Industrial Products Department

Certificate approved by:

G R Oliver
Manager
Industrial Products Department

ERA Technology Limited
Industrial Products Department
Cleeve Road Leatherhead Surrey KT22 7SA England
Telephone : +44 (0) 1372 367000
Fax: +44 (0) 1372 367112
E-mail : info@era.co.uk