



*CERTIFICATE OF COMPLIANCE*

**Number:** 5046/C549J  
**Dated:** 29 June 1998

**Issued to:** CMP PRODUCTS

**Apparatus:** PROTEX SURESEAL 2000 (PXSS2K)  
CABLE GLAND RANGE

*This is to certify that samples of the equipment defined above have been tested by ERA Technology Limited and found to comply with the following requirements:*

**BS EN 60529 : 1992 "Degrees of protection provided by enclosures (IP Code)" for a Degree of Protection IP66, IP67 AND IP68.**

*Full details are given in ERA Report No: 5046/549 dated June 1998.*

**Certificate prepared by:**

**A T Austin**  
Senior Technical Officer  
Industrial Products Department

**Certificate approved by:**

**G R Oliver**  
Manager  
Industrial Products Department

ERA Technology Limited  
Industrial Products Department  
Cleeve Road Leatherhead Surrey KT22 7SA England  
Telephone : +44 (0) 1372 367000  
Fax: +44 (0) 1372 367112  
E-mail : info@era.co.uk