



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert No. GYJ081071X

This is to certify that the product

manufactured by Cable Glands
CMP Products Limited
(Address: Glasshouse Street, St Peters, Newcastle-upon-Tyne, NE6 1BS, UK)

which model is A2F; A2FRC; SS2K; C**; E**; PX**

Ex marking Ex d II C/ Ex e II / Ex nR II / DIP A21 T_A

product standard /

drawing number See the attachment

has been inspected and certified by NEPSI, and that it conforms
to GB3836.1/2/3 - 2000、GB3836.8 - 2003、GB12476.1 - 2000

This Approval shall remain in force until 2013.05.07

- Remarks**
1. When the sign "X" is placed after the certificate number, it indicates that the product is subject to special conditions for safe use specified in the attachment to this certificate.
 2. Specifications are shown in the attachment to this certificate.
 3. The Ex markings are shown in the attachment to this certificate.
 4. Conditions for safe use are shown in the attachment to this certificate.

Director

National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date 2008.05.08



This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel:0086 21 64368180
Fax:0086 21 64844580



防爆合格证

证号:GYJ081071X

由 **CMP Products Limited**

制造的产品:

(地址: Glasshouse Street, St Peters, Newcastle-upon-Tyne, NE6 1BS, UK)

名称 电缆引入装置

型号规格 A2F; A2FRC; SS2K; C**; E**; PX**

防爆标志 Ex d II C / Ex e II / Ex nR II / DIP A21 T_A

产品标准 /

图样编号 见本证书附件

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB3836.1/2/3 - 2000、GB3836.8 - 2003、GB12476.1 - 2000标准, 特颁发此证。有效期自颁发日期起伍年内有效。

备注

1. 防爆合格证号后缀“X”表明该产品具有安全使用特定条件, 详见本证书附件。
2. 产品具体规格详见本证书附件。
3. 产品防爆标志详见本证书附件。
4. 产品使用注意事项见本证书附件。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期 二〇〇八年五月八日



本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: 0086 21 64368180
传真: 0086 21 64844580