

UL Online Certifications Directory

PJOX.E163112 Metal-clad Cable Connectors, Type MC

Page Bottom

Metal-clad Cable Connectors, Type MC

See General Information for Metal-clad Cable Connectors, Type MC

**CMP PRODUCTS, DIV OF
BRITISH ENGINES LTD**

E163112

GLASSHOUSE ST

ST PETERS

NEWCASTLE UPON TYNE

NE6 1BE ENGLAND, UNITED KINGDOM

Connectors for use with Metal-clad Cable (Type MC) with continuous corrugated aluminum cable or interlocking aluminum armor cable, or interlocking steel armor cable.

Cat. No.	Trade Size In.	Continuous Corrugated Aluminum Cable Diam In.		Interlocking Aluminum Armor Cable Diam In.		Interlocking Steel Armor Cable Diam In.	
		Min	Max	Min	Max	Min	Max
MCR050	1/2	0.437	—	—	0.669	—	0.669
MCR075	3/4	—	—	0.591	0.917	—	0.917
MCR20S	2	—	—	1.508	—	—	1.854
MCR25S	2-1/2	—	—	2.052	2.320	—	—
MCR100	1	0.775	—	0.775	—	0.775	1.150
MCR125	1-1/4	—	1.386	1.083	1.386	1.083	—
MCR150	1-1/2	—	1.618	1.320	—	—	—
MCR200	2	1.772	—	—	2.087	1.772	—
MCR250	2-1/2	—	—	—	2.545	2.247	—
MCR300	3	—	2.965	—	2.965	2.543	—
MCRA05S	1/2	—	0.5	—	—	—	—
MCRA050	1/2	0.510	—	—	0.669	—	0.669
MCRA075	3/4	—	—	0.591	0.917	—	0.917
MCRA20S	2	—	—	1.508	—	—	1.854
MCRA25S	2-1/2	—	—	2.052	2.320	—	—
MCRA100	1	0.775	—	0.775	—	0.775	1.150
MCRA125	1-1/4	—	1.386	1.083	1.386	1.083	—
MCRA150	1-1/2	—	1.618	1.320	—	—	—
MCRA200	2	1.772	—	—	2.087	1.772	—
MCRA250	2-1/2	—	—	—	2.545	2.247	—
MCRA300	3	—	2.965	—	2.965	2.543	—
MCRA350	3-1/2	2.913	3.485	—	—	—	—

MCRA400	4	2.913	3.485	—	—	—	—
---------	---	-------	-------	---	---	---	---

Last Updated on 2003-03-14

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2006 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2006 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

